

OFFICE OF THE SENIOR CHEMIST
Public Health Engineering Department Regional Laboratory, Ajmer (Raj)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No.Lab/Tech./ 2021-22/ 782

Date: 6.9.2021

To,
 Principal
 St. Joseph Sr. Sec. School
 Parbatpura, Ajmer

Not for Legal Purpose

District:- AJMER
 Tehsil:- AJMER

**Sample was not Collected
 by Laboratory**

Reference : Your Letter No. SJS/Corr/2021-22/1422 dated 02.09.2021

Sample collected by :- Sh Deepak Verma


Date of Receipt :- 02.09.2021

Lab Sample No.				P- 18
Source & Location:		Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	R.O. Water
				St. Joseph Sr. Sec. School , Parbatpura
Village/Town				Ajmer
Date Of Collection				02.09.2021
Date Of Examination				02.09.2021
1	pH	6.5 - 8.5	6.5 - 8.5	7.9
2	Turbidity (N.T.U.)	1	5	Nil
3	Colour	5	15	Nil
4	Odour	Agreeable		Agreeable
5	Total Alkalinity (as CaCO ₃)	200	600	100
6	Total Hardness (as CaCO ₃)	200	600	110
7	Chlorides (as Cl -)	250	1000	40
8	Fluorides (as F -)	1.0	1.5	0.2
9	Nitrate (as NO ₃ -)	45	No Relaxation	2
10	Total Dissolved Solids (T.D.S.)	500	2000	282
11	Residual Chlorine	0.2	1.0	Nil
		Applicable only when water is Chlorinated		

Note: All results except at Sr No. 1 to 4 are in mg /L


 Principal

St. Joseph Sr. Sec. School
 Parbatpura, Ajmer-305002
 SEMIS Code:08211503801


 (Dr. Archana Mathur)
Senior Chemist
 P.H.E.D. Lab.,Ajmer




कार्यालय नगर निगम, अजमेर
पृथ्वीराज मार्ग, अजमेर

क्रमांक : एच.ओ./2021-22/ 1163

दिनांक : 13/12/2021

प्रमाण पत्र

प्रमाणित किया जाता है कि स्वास्थ्य निरीक्षक की रिपोर्ट अनुसार सेंट जोसेफ उच्च माध्यमिक विद्यालय परबतपुरा, अजमेर में स्थित पीने के पानी की उचित व्यवस्था, पर्यावरण की दृष्टि से स्वच्छ एवं स्वस्थ वातावरण पाया गया एवं विद्यमान व्यवस्थाएँ यथा शौचालय अध्ययन कक्ष, पुस्तकालय इत्यादि समस्त कार्य संतोषजनक है।


स्वास्थ्य अधिकारी
नगर निगम, अजमेर